

Annexure C

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 19/2025

Dated: 01/09/2025

It is certified that an inspection team headed by MR. VIKAS KUMAR TECHNICAL MANAGER (Name of Officers with designation) from U.P JAL NIGAM (RURAL) PHED inspected the "Blue Bells", Ariyona, Faizabad Road, Akbarpur, Ambedkar Nagar, Uttar Pradesh - 224122 on 01/09/2025 of U.P JAL NIGAM LABORATORY AMBEDKAR NAGAR (PHED Lab) certified that the "Blue Bells", Ariyona, Faizabad Road, Akbarpur, Ambedkar Nagar, Uttar Pradesh - 224122 has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid for two years.



Technical Manager

District Level Water Analysis Laboratory

Signature with Seal: ...UP.JN.Ambedkar.Nagar

Name:VIKAS KUMAR.....

Designation:TECHNICAL MANAGER.....

Assistant Engineer of the Govt. Public Health Department (PHED)/Authorized officer of the Local Body

Name & Address of the Office / Department:

To,

Blue Bells,
Ariyona, Faizabad Road,
Akbarpur, Ambedkar Nagar,
Uttar Pradesh - 224122

Note: The certificate is to be issued by authorized officer /PHED lab/local bodies.





कार्यालय अधिशासी अभियन्ता खण्ड कार्यालय
उ० प्र० जल निगम (ग्रामीण),
अम्बेडकर नगर, उत्तर प्रदेश

पत्रांक : - 113/योजना/48-25

दिनांक: - 30/08/2025

क्र० सं०	विकास खंड	ग्राम पंचायत का नाम	राजस्व ग्राम का नाम	स्थल का नाम	भौतिक परीक्षण			रासायनिक परीक्षण (पी० पी० एम०)							
					पी० एच०	टी० दी० एस०	टर्बिंडटी	रंग	क्लोराइड	सम्पूर्ण कठोरता	एल्कलिनिटी	आयरन	नाइट्रेट	फ्लोराइड	जीवाणु
1	2	3	4	5	6	7	8		250-1000	200-600	200-600	0.3-1.0	0-45	1-1.5	0.01-0.05
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
1	अकबरपुर	अरियोना	अरियोना	"ब्लू बेल्स, अरियोना, फैजाबाद रोड, अकबरपुर, अम्बेडकर नगर, उत्तर प्रदेश "	7.79	190	0.44	रंग हीन	112	364	257	0.12	10.01	0.6	0.4

30.08.25
 Lab Chemist

Ramch. P.
 AE (Lab)